

1. Unique identification code of the product-type:

Multi Wall Metal System Chimney

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):

DINAK EI120+

1.0 Model 1.4404 / 316L	Ø80-300	T600 N1 D V2 L50040 G10
1.0 Model 1.4404 / 316L	Ø350-450	T600 N1 D V2 L50040 G15
1.0 Model 1.4404 / 316L	Ø500-600	T600 N1 D V2 L50040 G20
1.1 Model 1.4404 / 316L with seal	Ø80-600	T200 P1 W V2 L50040 O00
1.2 Model 1.4404 / 316L with external seal	Ø80-300	T600 H1 D V2 L50040 O30
1.2 Model 1.4404 / 316L with external seal	Ø350-450	T600 H1 D V2 L50040 O45
1.2 Model 1.4404 / 316L with external seal	Ø500-600	T600 H1 D V2 L50040 O60
2.0 Model 1.4521 / 444	Ø80-300	T600 N1 D V2 L99040 G10
2.0 Model 1.4521 / 444	Ø350-450	T600 N1 D V2 L99040 G15
2.0 Model 1.4521 / 444	Ø500-600	T600 N1 D V2 L99040 G20
2.1 Model 1.4521 / 444 with seal	Ø80-600	T200 P1 W V2 L99040 O00
2.2 Model 1.4521 / 444 with external seal	Ø80-300	T600 H1 D V2 L99040 O30
2.2 Model 1.4521 / 444 with external seal	Ø350-450	T600 H1 D V2 L99040 O45
2.2 Model 1.4521 / 444 with external seal	Ø500-600	T600 H1 D V2 L99040 O60
3.0 Model 1.4301 / 304	Ø80-300	T600 N1 D Vm L20040 G10
3.0 Model 1.4301 / 304	Ø350-450	T600 N1 D Vm L20040 G15
3.0 Model 1.4301 / 304	Ø500-600	T600 N1 D Vm L20040 G20
3.1 Model 1.4301 / 304 with seal	Ø80-600	T200 P1 W Vm L20040 O00
3.2 Model 1.4301 / 304 with external seal	Ø80-300	T600 H1 D Vm L20040 O30
3.2 Model 1.4301 / 304 with external seal	Ø350-450	T600 H1 D Vm L20040 O45
3.2 Model 1.4301 / 304 with external seal	Ø500-600	T600 H1 D Vm L20040 O60

3. Intended use or uses of the construction product, in accordance with the applicable designated technical specification, as foreseen by the manufacturer:

Convey the products of combustion from heating appliances to the outside atmosphere

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

DINAK S.A.
 Camiño do Laranxo, 19
 36216, Vigo (SPAIN)
 dinak@dinak.com
 tlf: +34 986 452 526

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in the Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended, Annex V:

System 2+
 System 4 (for terminals)

7. UK Approved product certification body TÜV SÜD BABT unlimited No.0168, performed the initial inspection of the manufacturing plant and of the factory production control and continuous surveillance; assessment and evaluation of factory production control; and issued the certificate of conformity of the factory production control

8. Declared performance

Essential Characteristics	Performance	Designated Standard
Compressive strength Chimney Sections, fittings and supports	Up to 8 m (See annex)	EN 1856-1:2009
Resistance to fire	Models 1.0. 2.0 and 3.0: Ø80-300: T600 – G10 Ø350-450: T600 – G15 Ø500-600: T600 – G20 Models 1.1. 2.1 and 3.1: Ø80-600: T200 – O00 Models 1.2. 2.2 and 3.2: Ø80-300: T600 – O30 Ø350-450: T600 – O45 Ø500-600: T600 – O60	EN 1856-1:2009
Gas tightness/leakage	Models 1.0. 2.0 and 3.0: N1 Models 1.1. 2.1 and 3.1: P1 Models 1.2. 2.2 and 3.2: H1	EN 1856-1:2009
Flow resistance of chimney sections, fittings and terminals	According to EN 13384-1	EN 1856-1:2009
Thermal resistance	Ø80-175: 0,745 -0,904 m ² K/W tested at 200°C Ø200-250: 0,939-0,995 m ² K/W tested at 200°C Ø300-550: 1,037-1,154 m ² K/W tested at 200°C Ø600: 1,167-1,207 m ² K/W tested at 200°C	EN 1856-1:2009
Thermal shock resistance Soot fire resistance	Models 1.0, 2.0 and 3.0: Yes Models 1.1, 1.2, 2.1, 2.2, 3.1 and 3.2: No	EN 1856-1:2009
Thermal performance under normal operating conditions	Models 1.0, 1.2, 2.0, 2.2, 3.0 and 3.2: T600 Models 1.1, 2.1 and 3.1: T200	
Flexural tensile strength (only for means of connection for chimney sections and fittings)	Up to 25 m (see annex)	EN 1856-1:2009
Non vertical installation	Only vertical installation	EN 1856-1:2009
Components subject to wind load	Maximum free standing height: 1 m above last support (see annex) Maximum spacing between lateral supports: 3 m (see annex)	EN 1856-1:2009
Durability Water and vapour diffusion resistance	Yes	EN 1856-1:2009
Condensate penetration resistance	Models 1.0, 1.2, 2.0, 2.2, 3.0 and 3.2: No Models 1.1, 2.1 and 3.1: Yes	

DOP-UKCA-EI120+-557

Against corrosion	Models 1.0, 1.1, 1.2, 2.0, 2.1 and 2.2: V2 Models 3.0, 3.1 and 3.2: Vm	
Freeze thaw resistance	Yes	EN 1856-1:2009

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Íñigo A. Canoa (General Manager)

Vigo, 1st September 2022